

Fiterman Hall Interior Wipe Sampling - Metals

Metals Wipe Samples Taken on 11-3-05

All results measured in ug/sq ft

Sample Location	Antimony	Barium	Beryllium	Cadmium	Chromium	Copper	Lead	Manganese	Nickel	Zinc
15th Floor Southeast Electrical Pane	1.96	371	ND	0.62	15.6	48.2	41.9	81.6	12.6	581
14th Floor Northwest Vent Cover	2.48	47.3	ND	ND	7.51	75	20	33.1	7.14	161
13th Floor Southwest Corridor Desk	2.95	60.1	ND	0.66	12.1	44.8	26.2	60.3	9.93	188
12th Floor West File Cabinet	3.18	44.2	ND	ND	8.57	34.1	32.3	39.2	7.81	110
11th Floor South Duct Work	8.23	1200	ND	0.7	31.6	93.9	74.9	189	22.8	1750
10th Floor North Corridor Floor	2.84	44.6	ND	0.65	6.88	43.8	23	50.9	6.06	143
9th Floor East Light Fixture	1.1	11.8	ND	ND	2.59	13.6	10.4	14	2.34	83.1
8th Floor East Table Top	1.38	25.6	ND	ND	2.6	14.1	8.96	15.5	4.05	26.4
7th Floor North Radiator Cover	14.2	87	ND	1.59	22.2	163	75.5	167	10.8	896
6th Floor West Radiator Cover	5.48	81.6	ND	1.42	13.4	72.9	53.6	80.9	19.6	338
5th Floor South Corridor Floor	6.97	108	ND	0.74	18.1	308	74	111	17.2	459
4th Floor East Radiator Cover	4.39	65.5	ND	1.06	16.4	62.6	62.4	128	25.4	312
3rd Floor Northeast Corridor Desk	14.8	108	ND	1.95	27.7	139	85.4	166	16.4	768
2nd Floor North Table Top	3.35	57.6	ND	ND	6.79	31.5	33.7	42.5	9.48	145
1st Floor Loading Dock Duct Work	ND	25.3	ND	ND	9.55	37.8	18.8	59.9	12.2	137
Basement Top Water Chiller Pipe	ND	48.5	ND	ND	1.54	16.6	3.89	13.4	4.24	233

TOTAL SAMPLES= 16